

Report of Analysis

Client:	PSEG	Date Collected:	10/16/24
Project:	Spring Valley 69-13kV Class H	Date Received:	10/16/24
Client Sample ID:	TRANSFORMER-PAD	SDG No.:	P4426
Lab Sample ID:	P4426-35	Matrix:	SOIL
Level (low/med):	low	% Solid:	100

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units(Dry Weight)	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	49.2		1	0.13	0.50	mg/Kg	10/18/24 09:15	10/22/24 19:49	SW6010	SW3050

Color Before:	Brown	Clarity Before:	Texture:	Medium
Color After:	Yellow	Clarity After:	Artifacts:	N/A
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits