

Report of Analysis

| | | | |
|-------------------|------------------------------|-----------------|----------|
| Client: | THE LEARNING CIRCLE YMCA | Date Collected: | 10/24/24 |
| Project: | Drinking Water Analysis 2024 | Date Received: | 10/24/24 |
| Client Sample ID: | TODDLER-1-SINK-A | SDG No.: | P4539 |
| Lab Sample ID: | P4539-01 | Matrix: | Water |
| Level (low/med): | low | % Solid: | 0 |

| Cas | Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. | Prep Met. |
|-----------|-----------|-------|------|----|------|------------|-------|----------------|----------------|----------|-----------|
| 7440-50-8 | Copper | 51.0 | | 1 | 0.79 | 2.00 | ug/L | 11/01/24 14:00 | 11/06/24 23:17 | 200.8 | |
| 7439-92-1 | Lead | 1.29 | | 1 | 0.27 | 1.00 | ug/L | 11/01/24 14:00 | 11/06/24 23:17 | 200.8 | |

| | | | | |
|---------------|---------------|-----------------|-------|------------|
| Color Before: | Colorless | Clarity Before: | Clear | Texture: |
| Color After: | Colorless | Clarity After: | Clear | Artifacts: |
| Comments: | Metals Group3 | | | |

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits