

## Report of Analysis

Client:	THE LEARNING CIRCLE YMCA	Date Collected:	10/24/24
Project:	Drinking Water Analysis 2024	Date Received:	10/24/24
Client Sample ID:	KITCHEN-FOOD-WASH-SINK-A	SDG No.:	P4539
Lab Sample ID:	P4539-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	199		1	0.79	2.00	ug/L	11/01/24 14:00	11/06/24 23:52	200.8	
7439-92-1	Lead	3.81		1	0.27	1.00	ug/L	11/01/24 14:00	11/06/24 23:52	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits