

Hit Summary Sheet
SW-846

SDG No.: P4539 **Order ID:** P4539
Client: THE LEARNING CIRCLE YMCA **Project ID:** Drinking Water Analysis 2024

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : TODDLER-1-SINK-A								
P4539-01	TODDLER-1-SINK-A	Water	Copper	51.0		0.79	2.00	ug/L
P4539-01	TODDLER-1-SINK-A	Water	Lead	1.29		0.27	1.00	ug/L
Client ID : TODDLER-1-SINK-B								
P4539-02	TODDLER-1-SINK-B	Water	Copper	43.0		0.79	2.00	ug/L
P4539-02	TODDLER-1-SINK-B	Water	Lead	0.61	J	0.27	1.00	ug/L
Client ID : TODDLER-2-SINK-A								
P4539-03	TODDLER-2-SINK-A	Water	Copper	54.4		0.79	2.00	ug/L
P4539-03	TODDLER-2-SINK-A	Water	Lead	0.60	J	0.27	1.00	ug/L
Client ID : TODDLER-2-SINK-B								
P4539-04	TODDLER-2-SINK-B	Water	Copper	38.9		0.79	2.00	ug/L
P4539-04	TODDLER-2-SINK-B	Water	Lead	0.38	J	0.27	1.00	ug/L
Client ID : TODDLER-3-SINK-A								
P4539-05	TODDLER-3-SINK-A	Water	Copper	108		0.79	2.00	ug/L
P4539-05	TODDLER-3-SINK-A	Water	Lead	0.55	J	0.27	1.00	ug/L
Client ID : TODDLER-3-SINK-B								
P4539-06	TODDLER-3-SINK-B	Water	Copper	121		0.79	2.00	ug/L
P4539-06	TODDLER-3-SINK-B	Water	Lead	0.69	J	0.27	1.00	ug/L
Client ID : TODDLER-4-SINK-A								
P4539-07	TODDLER-4-SINK-A	Water	Copper	104		0.79	2.00	ug/L
P4539-07	TODDLER-4-SINK-A	Water	Lead	0.90	J	0.27	1.00	ug/L
Client ID : TODDLER-4-SINK-B								
P4539-08	TODDLER-4-SINK-B	Water	Copper	118		0.79	2.00	ug/L
P4539-08	TODDLER-4-SINK-B	Water	Lead	0.91	J	0.27	1.00	ug/L
Client ID : KITCHEN-FOOD-WASH-SINK-A								
P4539-09	KITCHEN-FOOD-WASH-SINK	Water	Copper	199		0.79	2.00	ug/L
P4539-09	KITCHEN-FOOD-WASH-SINK	Water	Lead	3.81		0.27	1.00	ug/L
Client ID : KITCHEN-FOOD-WASH-SINK-B								
P4539-10	KITCHEN-FOOD-WASH-SINK	Water	Copper	162		0.79	2.00	ug/L
P4539-10	KITCHEN-FOOD-WASH-SINK	Water	Lead	1.07		0.27	1.00	ug/L
Client ID : KITCHEN-DISH-WASH-SINK-A								
P4539-11	KITCHEN-DISH-WASH-SINK	Water	Copper	170		0.79	2.00	ug/L

Hit Summary Sheet
SW-846

SDG No.: P4539

Order ID: P4539

Client: THE LEARNING CIRCLE YMCA

Project ID: Drinking Water Analysis 2024

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
P4539-11	KITCHEN-DISH-WASH-SINK-J	Water	Lead	1.23		0.27	1.00	ug/L
Client ID :	KITCHEN-DISH-WASH-SINK-B							
P4539-12	KITCHEN-DISH-WASH-SINK-J	Water	Copper	103		0.79	2.00	ug/L
P4539-12	KITCHEN-DISH-WASH-SINK-J	Water	Lead	0.43	J	0.27	1.00	ug/L
Client ID :	WATER-FOUNTAIN-A							
P4539-13	WATER-FOUNTAIN-A	Water	Copper	846		0.79	2.00	ug/L
Client ID :	WATER-FOUNTAIN-B							
P4539-14	WATER-FOUNTAIN-B	Water	Copper	536		0.79	2.00	ug/L
Client ID :	ADK-SINK-A							
P4539-15	ADK-SINK-A	Water	Copper	132		0.79	2.00	ug/L
P4539-15	ADK-SINK-A	Water	Lead	0.42	J	0.27	1.00	ug/L
Client ID :	ADK-SINK-B							
P4539-16	ADK-SINK-B	Water	Copper	121		0.79	2.00	ug/L
P4539-16	ADK-SINK-B	Water	Lead	0.30	J	0.27	1.00	ug/L
Client ID :	ROOM-12-SINK-A							
P4539-17	ROOM-12-SINK-A	Water	Copper	123		0.79	2.00	ug/L
P4539-17	ROOM-12-SINK-A	Water	Lead	3.93		0.27	1.00	ug/L
Client ID :	ROOM-12-SINK-B							
P4539-18	ROOM-12-SINK-B	Water	Copper	152		0.79	2.00	ug/L
P4539-18	ROOM-12-SINK-B	Water	Lead	2.14		0.27	1.00	ug/L
Client ID :	INFANT-2-SINK-A							
P4539-19	INFANT-2-SINK-A	Water	Copper	153		0.79	2.00	ug/L
P4539-19	INFANT-2-SINK-A	Water	Lead	0.33	J	0.27	1.00	ug/L
Client ID :	INFANT-2-SINK-B							
P4539-20	INFANT-2-SINK-B	Water	Copper	220		0.79	2.00	ug/L
P4539-20	INFANT-2-SINK-B	Water	Lead	0.43	J	0.27	1.00	ug/L