

Hit Summary Sheet SW-846

SDG No.: P4540 **Order ID:** P4540
Client: THE LEARNING CIRCLE YMCA **Project ID:** Drinking Water Analysis 2024

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : INFANT-2-SINK-C								
P4540-01	INFANT-2-SINK-C	Water	Copper	178		0.79	2.00	ug/L
P4540-01	INFANT-2-SINK-C	Water	Lead	0.49	J	0.27	1.00	ug/L
Client ID : INFANT-2-SINK-D								
P4540-02	INFANT-2-SINK-D	Water	Copper	263		0.79	2.00	ug/L
P4540-02	INFANT-2-SINK-D	Water	Lead	0.47	J	0.27	1.00	ug/L
Client ID : PRESCHOOL-1-SINK-A								
P4540-03	PRESCHOOL-1-SINK-A	Water	Copper	134		0.79	2.00	ug/L
P4540-03	PRESCHOOL-1-SINK-A	Water	Lead	0.86	J	0.27	1.00	ug/L
Client ID : PRESCHOOL-1-SINK-B								
P4540-04	PRESCHOOL-1-SINK-B	Water	Copper	103		0.79	2.00	ug/L
P4540-04	PRESCHOOL-1-SINK-B	Water	Lead	1.16		0.27	1.00	ug/L
Client ID : PRESCHOOL-2-SINK-A								
P4540-05	PRESCHOOL-2-SINK-A	Water	Copper	165		0.79	2.00	ug/L
P4540-05	PRESCHOOL-2-SINK-A	Water	Lead	0.88	J	0.27	1.00	ug/L
Client ID : PRESCHOOL-2-SINK-B								
P4540-06	PRESCHOOL-2-SINK-B	Water	Copper	145		0.79	2.00	ug/L
Client ID : PRESCHOOL-3-SINK-A								
P4540-07	PRESCHOOL-3-SINK-A	Water	Copper	140		0.79	2.00	ug/L
P4540-07	PRESCHOOL-3-SINK-A	Water	Lead	1.00		0.27	1.00	ug/L
Client ID : PRESCHOOL-3-SINK-B								
P4540-08	PRESCHOOL-3-SINK-B	Water	Copper	88.8		0.79	2.00	ug/L
P4540-08	PRESCHOOL-3-SINK-B	Water	Lead	0.89	J	0.27	1.00	ug/L
Client ID : PRESCHOOL-4-SINK-A								
P4540-09	PRESCHOOL-4-SINK-A	Water	Copper	65.1		0.79	2.00	ug/L
P4540-09	PRESCHOOL-4-SINK-A	Water	Lead	0.51	J	0.27	1.00	ug/L
Client ID : PRESCHOOL-4-SINK-B								
P4540-10	PRESCHOOL-4-SINK-B	Water	Copper	63.5		0.79	2.00	ug/L
P4540-10	PRESCHOOL-4-SINK-B	Water	Lead	0.64	J	0.27	1.00	ug/L
Client ID : INFANT-1-SINK-A								
P4540-11	INFANT-1-SINK-A	Water	Copper	172		0.79	2.00	ug/L
P4540-11	INFANT-1-SINK-A	Water	Lead	0.40	J	0.27	1.00	ug/L

Hit Summary Sheet
SW-846

SDG No.: P4540

Order ID: P4540

Client: THE LEARNING CIRCLE YMCA

Project ID: Drinking Water Analysis 2024

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : INFANT-1-SINK-B								
P4540-12	INFANT-1-SINK-B	Water	Copper	220		0.79	2.00	ug/L
Client ID : INFANT-1-SINK-C								
P4540-13	INFANT-1-SINK-C	Water	Copper	164		0.79	2.00	ug/L
Client ID : INFANT-1-SINK-D								
P4540-14	INFANT-1-SINK-D	Water	Copper	190		0.79	2.00	ug/L
P4540-14	INFANT-1-SINK-D	Water	Lead	0.33	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-1-SINK-A								
P4540-15	PREKINDERGARTEN-1-SINK- Water		Copper	91.2		0.79	2.00	ug/L
P4540-15	PREKINDERGARTEN-1-SINK- Water		Lead	0.43	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-1-SINK-B								
P4540-16	PREKINDERGARTEN-1-SINK- Water		Copper	54.1		0.79	2.00	ug/L
P4540-16	PREKINDERGARTEN-1-SINK- Water		Lead	0.39	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-2-SINK-A								
P4540-17	PREKINDERGARTEN-2-SINK- Water		Copper	160		0.79	2.00	ug/L
P4540-17	PREKINDERGARTEN-2-SINK- Water		Lead	0.39	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-2-SINK-B								
P4540-18	PREKINDERGARTEN-2-SINK- Water		Copper	133		0.79	2.00	ug/L
P4540-18	PREKINDERGARTEN-2-SINK- Water		Lead	0.36	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-3-SINK-A								
P4540-19	PREKINDERGARTEN-3-SINK- Water		Copper	124		0.79	2.00	ug/L
P4540-19	PREKINDERGARTEN-3-SINK- Water		Lead	0.97	J	0.27	1.00	ug/L
Client ID : PREKINDERGARTEN-3-SINK-B								
P4540-20	PREKINDERGARTEN-3-SINK- Water		Copper	64.0		0.79	2.00	ug/L
P4540-20	PREKINDERGARTEN-3-SINK- Water		Lead	2.01		0.27	1.00	ug/L
Client ID : TODDLER-BIG-ROOM-SINK-A								
P4540-21	TODDLER-BIG-ROOM-SINK- / Water		Copper	89.5		0.79	2.00	ug/L
P4540-21	TODDLER-BIG-ROOM-SINK- / Water		Lead	0.68	J	0.27	1.00	ug/L
Client ID : TODDLER-BIG-ROOM-SINK-B								
P4540-22	TODDLER-BIG-ROOM-SINK- F Water		Copper	28.6		0.79	2.00	ug/L
P4540-22	TODDLER-BIG-ROOM-SINK- F Water		Lead	0.40	J	0.27	1.00	ug/L
Client ID : STAFF-KITCHEN-A								
P4540-23	STAFF-KITCHEN-A	Water	Copper	172		0.79	2.00	ug/L

Hit Summary Sheet
SW-846

SDG No.: P4540

Order ID: P4540

Client: THE LEARNING CIRCLE YMCA

Project ID: Drinking Water Analysis 2024

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
P4540-23	STAFF-KITCHEN-A	Water	Lead	0.43	J	0.27	1.00	ug/L
Client ID : STAFF-KITCHEN-B								
P4540-24	STAFF-KITCHEN-B	Water	Copper	137		0.79	2.00	ug/L
Client ID : FB-10-24-24								
P4540-25	FB-10-24-24	Water	Copper	0.89	J	0.79	2.00	ug/L