



Atlas Environmental Lab, Corp
255 West 36th Street, Suite# 1503
New York, NY 10018
Phone: (212) 563-0400 Fax: (212) 563-0401
www.atlasenvironmentallab.com

Report of Bacteriological Examination (Heterotrophic Plate Count)

Client: Alliance Technical Group
Collected/Submitted by: Client
Project Name/No.: NYU Clinical Lab Water Testing 2025 / H25224389 / P4642
Project Address:
Matrix: Water

Lab ID: HP1024068
Date Received: 10/30/2024
Time Received: 14:25
Report Date: 11/1/2024

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
01	10/30/2024 @ 11:30	TH-401A-SINK-1	Incubated in: 10/30/2024 @ 14:55	3
HP1024068-1			Incubated out: 11/1/2024 @ 14:55	
02	10/30/2024 @ 11:30	TH-401A-SINK-2	Incubated in: 10/30/2024 @ 14:55	8
HP1024068-2			Incubated out: 11/1/2024 @ 14:55	
03	10/30/2024 @ 12:00	CC-10th -FL	Incubated in: 10/30/2024 @ 14:55	5
HP1024068-3			Incubated out: 11/1/2024 @ 14:55	
04	10/30/2024 @ 12:15	CC-3rd-FL	Incubated in: 10/30/2024 @ 14:55	4
HP1024068-4			Incubated out: 11/1/2024 @ 14:55	
05	10/30/2024 @ 12:15	7N-SKIRBALL	Incubated in: 10/30/2024 @ 14:55	2
HP1024068-5			Incubated out: 11/1/2024 @ 14:55	
06	10/30/2024 @ 12:15	TH-430-DI-1	Incubated in: 10/30/2024 @ 14:55	4
HP1024068-6			Incubated out: 11/1/2024 @ 14:55	



Atlas Environmental Lab, Corp
255 West 36th Street, Suite# 1503
New York, NY 10018
Phone: (212) 563-0400 Fax: (212) 563-0401
www.atlasenvironmentallab.com

Report of Bacteriological Examination (Heterotrophic Plate Count)

Client: Alliance Technical Group
Collected/Submitted by: Client
Project Name/No.: NYU Clinical Lab Water Testing 2025 / H25224389 / P4642
Project Address:
Matrix: Water

Lab ID: HP1024068
Date Received: 10/30/2024
Time Received: 2:25PM
Report Date: 11/1/2024

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
07	10/30/2024 @ 12:15	TH-430-DI-2	Incubated in: 10/30/2024 @ 14:55	2
HP1024068-7			Incubated out: 11/1/2024 @ 14:55	
08	10/30/2024 @ 12:15	TH-430-DI-3	Incubated in: 10/30/2024 @ 14:55	11
HP1024068-8			Incubated out: 11/1/2024 @ 14:55	
09	10/30/2024 @ 12:15	TH-404-DI-4	Incubated in: 10/30/2024 @ 14:55	16
HP1024068-9			Incubated out: 11/1/2024 @ 14:55	

AL

Method: Potable: SM 20, 21-23 9215 B (-04); Non Potable: SM 18-21 9215 B
ELAP Method 9136

Analyst: AD

Approved by: *Stephanie Pineda*

This laboratory report may not be reproduced, except in full, without the written approval of Atlas Environmental Lab corp.
Results relate only to the items tested.
NYS-ELAP#11999