Alliance
TECHNICAL GROUP

Matrix Spike Summary

Client:	Parkway Generation Operating LLC	**SDG No.:**	P4765
Project:	Linden Generating Station - LRSA	**Sample ID:**	P4763-01
Client ID:	Water Treatment DischargeMS	**Percent Solids for Spike Sample:**	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
Ammonia as N	mg/L	75-125	1.00		0.42		1	1	58	*	11/08/2024

Matrix Spike Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4763-01
Client ID:	Water Treatment DischargeMSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
Ammonia as N	mg/L	75-125	0.98		0.42		1	1	56	*	11/08/2024

Matrix Spike Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4765-03
Client ID:	DSN001MS	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
COD	mg/L	75-125	127		82.5		50.0	1	89		11/13/2024

Matrix Spike Summary

Client:	Parkway Generation Operating LLC		SDG No.:	P4765
Project:	Linden Generating Station - LRSA		Sample ID:	P4765-03
Client ID:	DSN001MSD		Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
COD	mg/L	75-125	129		82.5		50.0	1	93		11/13/2024