

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4735-01
Client ID:	EFFLUENTDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	4560		4550		1	0.13		11/07/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4757-01
Client ID:	001-WILLETS-BLVD(SEP)DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	48.0		48.7		1	1.45		11/08/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4763-01
Client ID:	Water Treatment DischargeDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	0.42		0.44		1	5		11/08/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4763-01
Client ID:	Water Treatment DischargeMSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	1.00		0.98		1	2		11/08/2024

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: P4765
Project: Linden Generating Station - LRSA	Sample ID: P4765-02
Client ID: DSN002DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.18		7.18		1	0		11/07/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4765-03
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	82.5		80.5		1	2.45		11/13/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4765-03
Client ID:	DSN001MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	127		129		1	1.56		11/13/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4765
Project:	Linden Generating Station - LRSA	Sample ID:	P4765-04
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.16		7.17		1	0.14		11/07/2024

Duplicate Sample Summary

Client: Parkway Generation Operating LLC Project: Linden Generating Station - LRSA Client ID: DSN003DUP	SDG No.: P4765 Sample ID: P4765-06 Percent Solids for Spike Sample: 0
--	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.00		7.01		1	0.14		11/07/2024