

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4767
Project:	Linden Generating Station - Towers	Sample ID:	P4757-01
Client ID:	001-WILLETS-BLVD(SEP)DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	48.0		48.7		1	1.45		11/08/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P4767
Project:	Linden Generating Station - Towers	Sample ID:	P4767-01
Client ID:	TOWER-2DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	3660		3700		1	1.01		11/07/2024