

### Laboratory Control Sample Summary

**Client:** Parkway Generation Operating LLC

**SDG No.:** P4767

**Project:** Linden Generating Station - Towers

**Run No.:** LB133353

| Analyte   | Units      | True Value | Result | Conc. Qualifier | % Recovery | Dilution Factor | Acceptance Limit %R | Analysis Date |
|-----------|------------|------------|--------|-----------------|------------|-----------------|---------------------|---------------|
| Sample ID | LB133353BS |            |        |                 |            |                 |                     |               |
| TSS       | mg/L       | 550        | 542    |                 | 98         | 1               | 90-110              | 11/08/2024    |

### Laboratory Control Sample Summary

**Client:** Parkway Generation Operating LLC

**SDG No.:** P4767

**Project:** Linden Generating Station - Towers

**Run No.:** LB133354

| Analyte   | Units      | True Value | Result | Conc. Qualifier | % Recovery | Dilution Factor | Acceptance Limit %R | Analysis Date |
|-----------|------------|------------|--------|-----------------|------------|-----------------|---------------------|---------------|
| Sample ID | LB133354BS |            |        |                 |            |                 |                     |               |
| TDS       | mg/L       | 100        | 96.0   |                 | 96         | 1               | 90-110              | 11/07/2024    |