



SAMPLE DATA

A

B

C

Report of Analysis

Client:	Tully Construction Co., Inc.	Date Collected:	12/05/24 08:22
Project:	10th Street & 2nd Avenue	Date Received:	12/05/24
Client Sample ID:	10TH-ST-SOIL	SDG No.:	P5112
Lab Sample ID:	P5112-02	Matrix:	SOIL
		% Solid:	100

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Corrosivity	6.41	H	1	0	0	pH		12/06/24 09:55	9045D
Ignitability	NO		1	0	0	oC		12/07/24 08:15	1030
Reactive Cyanide	0.0087	U	1	0.0087	0.050	mg/Kg	12/05/24 11:00	12/05/24 14:36	9012B
Reactive Sulfide	6.31	J	1	0.19	10.0	mg/Kg	12/06/24 08:50	12/06/24 12:45	9034

Comments: pH result reported at temperature 20.1 °C

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	P5112	OrderDate:	12/5/2024 10:43:00 AM
Client:	Tully Construction Co., Inc.	Project:	10th Street & 2nd Avenue
Contact:	Dean Devoe	Location:	L51,VOA Ref. #2 Soil

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
P5112-02	10TH-ST-SOIL	SOIL			12/05/24 08:22			12/05/24
			Corrosivity	9045D			12/06/24 09:55	
			Ignitability	1030			12/07/24 08:15	
			Reactive Sulfide	9034		12/06/24	12/06/24 12:45	
			Reactive Cyanide	9012B		12/05/24	12/05/24 14:36	