

Preparation Blank Summary

Client: VERINA CONSULTING GROUP, LLC

SDG No.: P5141

Project: Rotor Clip - PO# 5183.0001

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB133768BL Residual Chlorine	mg/L	< 0.0500	0.0500	U	0.016	0.1	12/05/2024
Sample ID: LB133770BL BOD5	mg/L	< 0.2000	0.2000	U	0.17	2.0	12/05/2024
Sample ID: LB133785BL Oil and Grease	mg/L	< 2.5000	2.5000	U	0.4	5.0	12/06/2024
Sample ID: LB133837BL COD	mg/L	< 5.0000	5.0000	U	2.35	10.0	12/09/2024
Sample ID: LB133838BL TSS	mg/L	< 2.0000	2.0000	U	1	4	12/09/2024
Sample ID: PB165461BL Ammonia as N	mg/L	< 0.0500	0.0500	U	0.045	0.1	12/09/2024
Sample ID: PB165498BL Cyanide	mg/L	< 0.0025	0.0025	U	0.00099	0.005	12/09/2024