

Laboratory Control Sample Summary

Client: Parkway Generation Operating LLC

SDG No.: P5142

Project: Linden Generating Station - Towers

Run No.: LB133838

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB133838BS							
TSS	mg/L	550	530		96	1	90-110	12/09/2024

Laboratory Control Sample Summary

Client: Parkway Generation Operating LLC

SDG No.: P5142

Project: Linden Generating Station - Towers

Run No.: LB133858

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB133858BS							
TDS	mg/L	100	92.0		92	1	90-110	12/09/2024