

Matrix Spike Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5143-01
Client ID:	DSN002MS	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
COD	mg/L	75-125	118		71.5		50.0	1	93		12/09/2024

Matrix Spike Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5143-01
Client ID:	DSN002MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
COD	mg/L	75-125	116		71.5		50.0	1	89		12/09/2024