

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5068-01
Client ID:	14B-1DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	4500		4530		1	0.66		12/09/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5074-02
Client ID:	COMPDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	1250		1210		1	3.02		12/05/2024

Duplicate Sample Summary

Client: Parkway Generation Operating LLC Project: Linden Generating Station - LRSA Client ID: DSN002DUP	SDG No.: P5143 Sample ID: P5143-01 Percent Solids for Spike Sample: 0
--	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	71.5		72.5		1	1.39		12/09/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5143-01
Client ID:	DSN002MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	118		116		1	1.71		12/09/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5143-02
Client ID:	DSN002DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.87		6.88		1	0.15		12/05/2024

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: P5143
Project: Linden Generating Station - LRSA	Sample ID: P5143-04
Client ID: DSN001DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.98		6.97		1	0.14		12/05/2024

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	P5143
Project:	Linden Generating Station - LRSA	Sample ID:	P5143-06
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.83		6.82		1	0.15		12/05/2024