

Report of Analysis

Client:	PSEG	Date Collected:	12/06/24 10:55
Project:	Oradell Gas	Date Received:	12/06/24
Client Sample ID:	120324-A	SDG No.:	P5170
Lab Sample ID:	P5170-02	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
pH	6.13	H	1	0	0	pH		12/07/24 08:47	9040C

Comments: pH result reported at temperature 20.6 °C

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits