

## Report of Analysis

Client:	Willets Point Asphalt Corporation	Date Collected:	12/17/24 13:30
Project:	SPDES	Date Received:	12/18/24
Client Sample ID:	002A(JUL-DEC)	SDG No.:	P5329
Lab Sample ID:	P5329-02	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
TSS	201		1	1.00	4.00	mg/L		12/19/24 09:15	SM 2540 D-15

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits