



Atlas Environmental Lab, Corp  
 255 West 36th Street, Suite# 1503  
 New York, NY 10018  
 Phone: (212) 563-0400 Fax: (212) 563-0401  
 www.atlasenvironmentallab.com

## Report of Bacteriological Examination (Heterotrophic Plate Count)

**Client:** Chemtech  
**Collected/Submitted by:** Client  
**Project Name/No.:** NYU Clinical Lab Water Testing 2025 / H25224389 / P5397  
**Project Address:**  
**Matrix:** Water

**Lab ID:** HP1224052  
**Date Received:** 12/30/2024  
**Time Received:** 13:40  
**Report Date:** 1/1/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
01	12/30/2024 @11:30	TH401A-CYTOLOGY-SINK-1	Incubated in: 12/30/2024 @ 14:10	11
HP1224052-1			Incubated out: 1/1/2025 @ 14:10	
02	12/30/2024 @11:30	TH401A-CYTOLOGY-SINK-2	Incubated in: 12/30/2024 @ 14:10	4
HP1224052-2			Incubated out: 1/1/2025 @ 14:10	
03	12/30/2024 @12:00	CANCER-CENTER-CYTOLOGY-10	Incubated in: 12/30/2024 @ 14:10	9
HP1224052-3			Incubated out: 1/1/2025 @ 14:10	
04	12/30/2024 @12:15	CANCER-CENTER-CYTOLOGY-3R	Incubated in: 12/30/2024 @ 14:10	5
HP1224052-4			Incubated out: 1/1/2025 @ 14:10	
05	12/30/2024 @12:15	SKIRBALL-FGP-CYTOLOGY	Incubated in: 12/30/2024 @ 14:10	2
HP1224052-5			Incubated out: 1/1/2025 @ 14:10	
06	12/30/2024 @12:15	TH430-HISTOLOGY-DI-1	Incubated in: 12/30/2024 @ 14:10	12
HP1224052-6			Incubated out: 1/1/2025 @ 14:10	



Atlas Environmental Lab, Corp  
255 West 36th Street, Suite# 1503  
New York, NY 10018  
Phone: (212) 563-0400 Fax: (212) 563-0401  
www.atlasenvironmentallab.com

## Report of Bacteriological Examination (Heterotrophic Plate Count)

**Client:** Chemtech  
**Collected/Submitted by:** Client  
**Project Name/No.:** NYU Clinical Lab Water Testing 2025 / H25224389 / P5397  
**Project Address:**  
**Matrix:** Water

**Lab ID:** HP1224052  
**Date Received:** 12/30/2024  
**Time Received:** 13:40  
**Report Date:** 1/1/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
07	12/30/2024 @12:15	TH430-HISTOLOGY-DI-2	Incubated in: 12/30/2024 @ 14:10	9
HP1224052-7			Incubated out: 1/1/2025 @ 14:10	
08	12/30/2024 @12:15	TH430-HISTOLOGY-DI-3	Incubated in: 12/30/2024 @ 14:10	7
HP1224052-8			Incubated out: 1/1/2025 @ 14:10	
09	12/30/2024 @12:15	TH404-IHC-DI-4	Incubated in: 12/30/2024 @ 14:10	7
HP1224052-9			Incubated out: 1/1/2025 @ 14:10	

TC

Method: Potable: SM 20, 21-23 9215 B (-04); Non Potable: SM 18-21 9215 B  
ELAP Method 9136

Analyst: JD

Approved by: *Stephanie Pineda*

This laboratory report may not be reproduced, except in full, without the written approval of Atlas Environmental Lab corp.  
Results relate only to the items tested.  
NYS-ELAP#11999