

Report of Analysis

Client:	Ardmore Chemical	Date Collected:	01/10/25 10:15
Project:	PVSC Monthly 2025	Date Received:	01/10/25
Client Sample ID:	EFF-WASTE WATER	SDG No.:	Q1066
Lab Sample ID:	Q1066-02	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
BOD5	910		1	0.17	2.00	mg/L		01/10/25 16:20	SM 5210 B-16
TSS	16.8		1	1.00	4.00	mg/L		01/13/25 10:15	SM 2540 D-15

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits