

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	01/16/25 10:10
Project:	Linden Generating Station - LRSA	Date Received:	01/16/25
Client Sample ID:	TOWER-2	SDG No.:	Q1112
Lab Sample ID:	Q1112-03	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
TDS	2500		1	1.00	10.0	mg/L		01/16/25 12:30	SM 2540 C-15
TSS	2.40	J	1	1.00	4.00	mg/L		01/17/25 09:45	SM 2540 D-15

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits