

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1112
Project:	Linden Generating Station - LRSA	Sample ID:	Q1111-01
Client ID:	DRAIN WATER TANK-1DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	290		294		1	1.37		01/17/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1112
Project:	Linden Generating Station - LRSA	Sample ID:	Q1112-03
Client ID:	TOWER-2DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	2500		2540		1	1.75		01/16/2025