

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1113
Project:	Linden Generating Station - LRSA	Sample ID:	Q1100-02
Client ID:	COMPDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	706		700		1	0.87		01/16/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q1113
Project: Linden Generating Station - LRSA	Sample ID: Q1111-01
Client ID: DRAIN WATER TANK-1DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	290		294		1	1.37		01/17/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q1113
Project: Linden Generating Station - LRSA	Sample ID: Q1113-01
Client ID: DSN002DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	3.40	OR	3.30	OR	1	3		01/17/2025
COD	mg/L	+/-20	54.3		55.3		1	1.82		01/22/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q1113
Project: Linden Generating Station - LRSA	Sample ID: Q1113-01
Client ID: DSN002MSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	4.30	OR	4.10	OR	1	5		01/17/2025
COD	mg/L	+/-20	102		101		1	0.99		01/22/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1113
Project:	Linden Generating Station - LRSA	Sample ID:	Q1113-02
Client ID:	DSN002DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.98		6.97		1	0.14		01/16/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1113
Project:	Linden Generating Station - LRSA	Sample ID:	Q1113-04
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.12		7.13		1	0.14		01/16/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1113
Project:	Linden Generating Station - LRSA	Sample ID:	Q1113-06
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.00		7.00		1	0		01/16/2025