



A

B

C

SAMPLE DATA

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 10:20
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM2016-SINK	SDG No.:	Q1157
Lab Sample ID:	Q1157-01	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.086	HJ	1	0.016	0.10	mg/L		01/23/25 09:36	SM 4500-Cl G-11
Turbidity	0.77	J	1	0.075	1.00	NTU		01/23/25 14:44	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 10:15
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM2010-SINK	SDG No.:	Q1157
Lab Sample ID:	Q1157-02	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.048	HJ	1	0.016	0.10	mg/L		01/23/25 09:48	SM 4500-Cl G-11
Turbidity	0.64	J	1	0.075	1.00	NTU		01/23/25 14:52	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 10:05
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM2011-RH-SINK	SDG No.:	Q1157
Lab Sample ID:	Q1157-03	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.048	HJ	1	0.016	0.10	mg/L		01/23/25 09:51	SM 4500-Cl G-11
Turbidity	0.61	J	1	0.075	1.00	NTU		01/23/25 14:56	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 09:50
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-LH-DRINKING FOUNTAIN	SDG No.:	Q1157
Lab Sample ID:	Q1157-04	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.030	HJ	1	0.016	0.10	mg/L		01/23/25 09:54	SM 4500-Cl G-11
Turbidity	0.94	J	1	0.075	1.00	NTU		01/23/25 15:00	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 10:00
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM2019-EYEWASH	SDG No.:	Q1157
Lab Sample ID:	Q1157-05	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.11	H	1	0.016	0.10	mg/L		01/23/25 09:57	SM 4500-Cl G-11
Turbidity	0.71	J	1	0.075	1.00	NTU		01/23/25 15:04	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 09:40
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM2040-SINK	SDG No.:	Q1157
Lab Sample ID:	Q1157-06	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.058	HJ	1	0.016	0.10	mg/L		01/23/25 10:06	SM 4500-Cl G-11
Turbidity	0.67	J	1	0.075	1.00	NTU		01/23/25 15:08	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	01/22/25 09:45
Project:	Kingsboro B28 Water Sampling	Date Received:	01/22/25
Client Sample ID:	B2-W10-RM-2035-SINK	SDG No.:	Q1157
Lab Sample ID:	Q1157-07	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.20	H	1	0.016	0.10	mg/L		01/23/25 10:09	SM 4500-Cl G-11
Turbidity	0.74	J	1	0.075	1.00	NTU		01/23/25 15:12	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q1157	OrderDate:	1/22/2025 3:12:00 PM
Client:	CHA Companies, Inc.	Project:	Kingsboro B28 Water Sampling
Contact:	Carrie Robinson	Location:	E11

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q1157-01	B2-W10-RM2016-SIN K	Water	Residual Chlorine	SM4500 CI G	01/22/25 10:20		01/23/25 09:36	01/22/25
			Turbidity	SM2130 B			01/23/25 14:44	
Q1157-02	B2-W10-RM2010-SIN K	Water	Residual Chlorine	SM4500 CI G	01/22/25 10:15		01/23/25 09:48	01/22/25
			Turbidity	SM2130 B			01/23/25 14:52	
Q1157-03	B2-W10-RM2011-RH- SINK	Water	Residual Chlorine	SM4500 CI G	01/22/25 10:05		01/23/25 09:51	01/22/25
			Turbidity	SM2130 B			01/23/25 14:56	
Q1157-04	B2-W10-LH-DRINKIN G FOUNTAIN	Water	Residual Chlorine	SM4500 CI G	01/22/25 09:50		01/23/25 09:54	01/22/25
			Turbidity	SM2130 B			01/23/25 15:00	
Q1157-05	B2-W10-RM2019-EYE WASH	Water	Residual Chlorine	SM4500 CI G	01/22/25 10:00		01/23/25 09:57	01/22/25

LAB CHRONICLE

Q1157-06	B2-W10-RM2040-SIN K	Water	Turbidity	SM2130 B		01/23/25 15:04	01/22/25 09:40	01/22/25
			Residual Chlorine	SM4500 Cl G		01/23/25 10:06		
			Turbidity	SM2130 B		01/23/25 15:08		
Q1157-07	B2-W10-RM-2035-SIN K	Water					01/22/25 09:45	01/22/25
			Residual Chlorine	SM4500 Cl G		01/23/25 10:09		
			Turbidity	SM2130 B		01/23/25 15:12		