

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1301
Project:	Linden Generating Station - 402	Sample ID:	LB134583BS
Client ID:	LB134583BSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TPH	mg/L	+/-18	16.9		17.0		1	0.59		02/05/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1301
Project:	Linden Generating Station - 402	Sample ID:	Q1301-01
Client ID:	402DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.32		7.33		1	0.14		02/05/2025