

Preparation Blank Summary

Client: Parkway Generation Operating LLC

SDG No.: Q1325

Project: Linden Generating Station - LRSA

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB134607BL TDS	mg/L	< 5.0000	5.0000	U	1.0	10	02/06/2025
Sample ID: LB134609BL Hexavalent Chromium	mg/L	< 0.0050	0.0050	U	0.003	0.01	02/06/2025
Sample ID: LB134610BL BOD5	mg/L	< 0.2000	0.2000	U	0.17	2.0	02/06/2025
Sample ID: LB134631BL COD	mg/L	< 5.0000	5.0000	U	2.35	10.0	02/07/2025
Sample ID: LB134646BL TSS	mg/L	1	2.0000	J	1	4	02/10/2025
Sample ID: PB166612BL Ammonia as N	mg/L	< 0.0500	0.0500	U	0.045	0.1	02/07/2025
Sample ID: PB166642BL Phenolics	mg/L	< 0.0250	0.0250	U	0.023	0.05	02/10/2025
Sample ID: PB166643BL Sulfide	mg/L	< 0.5000	0.5000	U	0.43	1.0	02/10/2025