

Preparation Blank Summary

Client: Parkway Generation Operating LLC

SDG No.: Q1326

Project: Linden Generating Station - Towers

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB134607BL							
TDS	mg/L	< 5.0000	5.0000	U	1.0	10	02/06/2025
Sample ID: LB134646BL							
TSS	mg/L	1	2.0000	J	1	4	02/10/2025