

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1326
Project:	Linden Generating Station - Towers	Sample ID:	Q1316-02
Client ID:	002-35TH-AVE(FEB)DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	48.3		47.0		1	2.73		02/10/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC Project: Linden Generating Station - Towers Client ID: TOWER-2DUP	SDG No.: Q1326 Sample ID: Q1326-02 Percent Solids for Spike Sample: 0
---	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	2470		2470		1	0.12		02/06/2025