

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	02/24/25 07:30
Project:	Linden Gen - NJDEP WW Discharge Permit	Date Received:	02/24/25
Client Sample ID:	LRSA-MOD-1	SDG No.:	Q1417
Lab Sample ID:	Q1417-01	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Dissolved Hexavalent Chromium	0.010	U	1	0.0030	0.010	mg/L		02/25/25 12:14	7196A
Oil and Grease	5.00	U	1	0.40	5.00	mg/L		02/28/25 10:25	1664A
Phenolics	0.050	U	1	0.015	0.050	mg/L	02/28/25 09:25	02/28/25 12:55	9065
Sulfide	1.00	U	1	0.43	1.00	mg/L	02/26/25 09:05	02/26/25 11:26	9034
TPH	5.00	U	1	0.40	5.00	mg/L		02/28/25 09:00	1664A

Comments:

U = Not Detected
LOQ = Limit of Quantitation
MDL = Method Detection Limit
LOD = Limit of Detection
D = Dilution
Q = indicates LCS control criteria did not meet requirements
H = Sample Analysis Out Of Hold Time

J = Estimated Value
B = Analyte Found in Associated Method Blank
* = indicates the duplicate analysis is not within control limits.
E = Indicates the reported value is estimated because of the presence of interference.
OR = Over Range
N = Spiked sample recovery not within control limits