

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134797

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	lb134797BS							
Hexavalent Chromium	mg/L	0.5	0.51		102	1	90-111	02/25/2025

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134845

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB134845BS							
TPH	mg/L	20.0	16.8		84	1	78-114	02/28/2025

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134845

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB134845BSD							
TPH	mg/L	20.0	17.0		85	1	78-114	02/28/2025

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134850

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB134850BS							
Oil and Grease	mg/L	20.0	17.0		85	1	78-114	02/28/2025

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134808

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	PB166866BS							
Sulfide	mg/L	25	23.8		95	1	80-120	02/26/2025

Laboratory Control Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1417
Project:	Linden Gen - NJDEP WW Discharge Permit	Run No.:	LB134857

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	PB166867BS							
Phenolics	mg/L	1	0.99		99	1	80-120	02/28/2025