

Duplicate Sample Summary

Client: Major Products Project: Floor Drain Water 2025 Client ID: COMPDUP	SDG No.: Q1493 Sample ID: Q1491-02 Percent Solids for Spike Sample: 0
--	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	813		818		1	0.6		03/05/2025

Duplicate Sample Summary

Client:	Major Products	SDG No.:	Q1493
Project:	Floor Drain Water 2025	Sample ID:	Q1497-02
Client ID:	002-35TH-AVE(FEB)DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	38.6		39.0		1	1.03		03/06/2025