

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	03/05/25
Project:	Linden Generating Station - 402	Date Received:	03/05/25
Client Sample ID:	402	SDG No.:	Q1499
Lab Sample ID:	Q1499-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-97-6	Mercury	0.20	U	1	0.022	0.20	ug/L	03/12/25 15:56	03/12/25 19:07	E245.1	
7440-28-0	Thallium	20.0	U	1	2.21	20.0	ug/L	03/06/25 08:40	03/11/25 14:04	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Cloudy	Texture:
Color After:	Colorless	Clarity After:	Cloudy	Artifacts:
Comments:	Mercury			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits