

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q1512
Project: Linden Generating Station - Towers	Sample ID: Q1512-02
Client ID: TOWERS-2DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	3090		3100		1	0.19		03/06/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1512
Project:	Linden Generating Station - Towers	Sample ID:	Q1513-05
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	12.4		12.5		1	0.8		03/10/2025