

Hit Summary Sheet SW-846

SDG No.: Q1561 **Order ID:** Q1561
Client: Cradles to Crayons **Project ID:** Drinking Water Testing 2025

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : INFANT-ROOM-A								
Q1561-01	INFANT-ROOM-A	Water	Copper	201		0.79	2.00	ug/L
Q1561-01	INFANT-ROOM-A	Water	Lead	37.7	D	0.54	2.00	ug/L
Client ID : WADDLERS-A								
Q1561-02	WADDLERS-A	Water	Copper	326		0.79	2.00	ug/L
Q1561-02	WADDLERS-A	Water	Lead	1.38		0.27	1.00	ug/L
Client ID : PRE-TODDLER-ROOM-SINK-A								
Q1561-03	PRE-TODDLER-ROOM-SINK-/	Water	Copper	288		0.79	2.00	ug/L
Q1561-03	PRE-TODDLER-ROOM-SINK-/	Water	Lead	1.09		0.27	1.00	ug/L
Client ID : LONGE-A								
Q1561-04	LONGE-A	Water	Copper	533		0.79	2.00	ug/L
Q1561-04	LONGE-A	Water	Lead	0.34	J	0.27	1.00	ug/L
Client ID : TODDLERS-SINK-A								
Q1561-05	TODDLERS-SINK-A	Water	Copper	321		0.79	2.00	ug/L
Q1561-05	TODDLERS-SINK-A	Water	Lead	1.59		0.27	1.00	ug/L
Client ID : STAFF-BATHROOM-A								
Q1561-06	STAFF-BATHROOM-A	Water	Copper	239		0.79	2.00	ug/L
Q1561-06	STAFF-BATHROOM-A	Water	Lead	0.56	J	0.27	1.00	ug/L
Client ID : SICK-BATHROOM-A								
Q1561-07	SICK-BATHROOM-A	Water	Copper	141		0.79	2.00	ug/L
Q1561-07	SICK-BATHROOM-A	Water	Lead	1.18	JD	0.54	2.00	ug/L
Client ID : DIRECTORS-OFFICE-A								
Q1561-08	DIRECTORS-OFFICE-A	Water	Copper	247		0.79	2.00	ug/L
Client ID : PRE-K-BATHROOM-A								
Q1561-09	PRE-K-BATHROOM-A	Water	Copper	229		0.79	2.00	ug/L
Q1561-09	PRE-K-BATHROOM-A	Water	Lead	0.27	J	0.27	1.00	ug/L
Client ID : KINDERGARDEN-BATHROOM-A								
Q1561-10	KINDERGARDEN-BATHROOM	Water	Copper	341		0.79	2.00	ug/L
Q1561-10	KINDERGARDEN-BATHROOM	Water	Lead	1.27		0.27	1.00	ug/L
Client ID : 2ND-FLOOR-WATER-FOUNTAIN								
Q1561-11	2ND-FLOOR-WATER-FOUNTA	Water	Copper	760		0.79	2.00	ug/L

Hit Summary Sheet
SW-846

SDG No.: Q1561

Order ID: Q1561

Client: Cradles to Crayons

Project ID: Drinking Water Testing 2025

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	1ST-FLOOR-WATER-FOUNTAIN							
Q1561-12	1ST-FLOOR-WATER-FOUNTAIN	Water	Copper	811		0.79	2.00	ug/L



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	INFANT-ROOM-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	201		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 16:11	200.8	
7439-92-1	Lead	37.7	D*	2	0.54	2.00	ug/L	03/14/25 10:05	03/18/25 17:49	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	WADDLERS-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	326		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 16:39	200.8	
7439-92-1	Lead	1.38	*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 16:39	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	PRE-TODDLER-ROOM-SINK-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	288		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 16:53	200.8	
7439-92-1	Lead	1.09	*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 16:53	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	LONGE-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	533		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 16:57	200.8	
7439-92-1	Lead	0.34	J*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 16:57	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	TODDLERS-SINK-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	321		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:01	200.8	
7439-92-1	Lead	1.59	*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:01	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	STAFF-BATHROOM-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	239		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:04	200.8	
7439-92-1	Lead	0.56	J*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:04	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	SICK-BATHROOM-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	141		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:08	200.8	
7439-92-1	Lead	1.18	JD*	2	0.54	2.00	ug/L	03/14/25 10:05	03/18/25 18:11	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	DIRECTORS-OFFICE-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	247		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:11	200.8	
7439-92-1	Lead	0.27	U*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:11	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	PRE-K-BATHROOM-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	229		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:15	200.8	
7439-92-1	Lead	0.27	J*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:15	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	KINDERGARDEN-BATHROOM-A	SDG No.:	Q1561
Lab Sample ID:	Q1561-10	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	341		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:19	200.8	
7439-92-1	Lead	1.27	*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:19	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	2ND-FLOOR-WATER-FOUNTAIN	SDG No.:	Q1561
Lab Sample ID:	Q1561-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	760		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:22	200.8	
7439-92-1	Lead	0.27	U*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:22	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	1ST-FLOOR-WATER-FOUNTAIN	SDG No.:	Q1561
Lab Sample ID:	Q1561-12	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	811		1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:26	200.8	
7439-92-1	Lead	0.27	U*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:26	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Cradles to Crayons	Date Collected:	03/13/25
Project:	Drinking Water Testing 2025	Date Received:	03/13/25
Client Sample ID:	FB	SDG No.:	Q1561
Lab Sample ID:	Q1561-13	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	0.79	U	1	0.79	2.00	ug/L	03/14/25 10:05	03/18/25 17:46	200.8	
7439-92-1	Lead	0.27	U*	1	0.27	1.00	ug/L	03/14/25 10:05	03/18/25 17:46	200.8	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q1561	OrderDate:	3/13/2025 10:21:50 AM
Client:	Cradles to Crayons	Project:	Drinking Water Testing 2025
Contact:	Cheryl Palhares	Location:	F11

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q1561-01	INFANT-ROOM-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-02	WADDLERS-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-03	PRE-TODDLER-ROOM-SINK-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-04	LONGE-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-05	TODDLERS-SINK-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-06	STAFF-BATHROOM-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-07	SICK-BATHROOM-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-08	DIRECTORS-OFFICE-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-09	PRE-K-BATHROOM-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-10	KINDERGARDEN-BATHROOM-A	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
Q1561-11	2ND-FLOOR-WATER-FOUNTAIN	Water			03/13/25			03/13/25

LAB CHRONICLE

Q1561-12	1ST-FLOOR-WATER-F OUNTAIN	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
			Metals Group3	200.8		03/14/25	03/18/25	
Q1561-13	FB	Water	Metals Group3	200.8	03/13/25	03/14/25	03/18/25	03/13/25
			Metals Group3	200.8		03/14/25	03/18/25	