



284 Sheffield Street, Mountainside, NJ 07092 Phone: 908 789 8900 Fax: 908 789 8922

CASE NARRATIVE

CHA Companies, Inc.

Project Name: NYSOMH Emergency Service

Project # N/A

Chemtech Project # Q1759

Test Name: Turbidity,Residual Chlorine

A. Number of Samples and Date of Receipt:

7 Water samples were received on 04/09/2025.

B. Parameters:

According to the Chain of Custody document, the following analyses were requested: Residual Chlorine and Turbidity. This data package contains results for Turbidity, Residual Chlorine.

C. Analytical Techniques:

The analysis of Turbidity was based on method SM2130 B and The analysis of Residual Chlorine was based on method SM4500 Cl G.

D. QA/ QC Samples:

The Holding Times were met for all samples except for B2-W8-LH-DRINKING-FOUNTAIN of Residual Chlorine, for B2-W8-RM1010-SINK of Residual Chlorine.for B2-W8-RM1011-RHSINK of Residual Chlorine.for B2-W8-RM1016-SINK of Residual Chlorine.for B2-W8-RM1019-EYEWASH of Residual Chlorine.for B2-W8-RM1040-SINK of Residual Chlorine.for B2-W8-RM1041-SINK of Residual Chlorine as samples were receive out of holding time.

The Blank Spike met requirements for all samples.

The Duplicate analysis met criteria for all samples.

The Matrix Spike analysis met criteria for all samples.

The Matrix Spike Duplicate analysis met criteria for all samples.

The Blank analysis did not indicate the presence of lab contamination.

The Calibration met the requirements.

E. Additional Comments:

I certify that the data package is in compliance with the terms and conditions of the contract, both technically and for completeness, for other than the conditions detailed above. The laboratory manager or his designee, as verified by the following signature has authorized release of the data contained in this hard copy data package.

Signature_____