



A

B

C

# SAMPLE DATA

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:20
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1016-SINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-01	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.26	H	1	0.023	0.10	mg/L		04/10/25 09:26	SM 4500-Cl G-11
Turbidity	2.30		1	0.15	1.00	NTU		04/10/25 14:36	SM 2130 B-11

Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:25
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1010-SINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-02	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.14	H	1	0.023	0.10	mg/L		04/10/25 09:38	SM 4500-Cl G-11
Turbidity	1.60		1	0.15	1.00	NTU		04/10/25 14:44	SM 2130 B-11

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:32
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1011-RHSINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-03	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.22	H	1	0.023	0.10	mg/L		04/10/25 09:41	SM 4500-Cl G-11
Turbidity	2.03		1	0.15	1.00	NTU		04/10/25 14:48	SM 2130 B-11

Comments:

U = Not Detected  
LOQ = Limit of Quantitation  
MDL = Method Detection Limit  
LOD = Limit of Detection  
D = Dilution  
Q = indicates LCS control criteria did not meet requirements  
H = Sample Analysis Out Of Hold Time

J = Estimated Value  
B = Analyte Found in Associated Method Blank  
\* = indicates the duplicate analysis is not within control limits.  
E = Indicates the reported value is estimated because of the presence of interference.  
OR = Over Range  
N = Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:38
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-LH-DRINKING-FOUNTAIN	SDG No.:	Q1759
Lab Sample ID:	Q1759-04	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.023	HJ	1	0.023	0.10	mg/L		04/10/25 09:44	SM 4500-Cl G-11
Turbidity	2.06		1	0.15	1.00	NTU		04/10/25 14:52	SM 2130 B-11

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:45
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1019-EYEWASH	SDG No.:	Q1759
Lab Sample ID:	Q1759-05	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.077	HJ	1	0.023	0.10	mg/L		04/10/25 09:47	SM 4500-Cl G-11
Turbidity	1.28		1	0.15	1.00	NTU		04/10/25 14:56	SM 2130 B-11

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:53
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1040-SINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-06	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.15	H	1	0.023	0.10	mg/L		04/10/25 09:56	SM 4500-Cl G-11
Turbidity	1.49		1	0.15	1.00	NTU		04/10/25 15:00	SM 2130 B-11

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:58
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1041-SINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-07	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.29	H	1	0.023	0.10	mg/L		04/10/25 09:59	SM 4500-Cl G-11
Turbidity	1.82		1	0.15	1.00	NTU		04/10/25 15:04	SM 2130 B-11

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits



## LAB CHRONICLE

<b>OrderID:</b>	Q1759	<b>OrderDate:</b>	4/9/2025 2:34:00 PM
<b>Client:</b>	CHA Companies, Inc.	<b>Project:</b>	NYSOMH Emergency Service
<b>Contact:</b>	Carrie Robinson	<b>Location:</b>	L41

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q1759-01	B2-W8-RM1016-SINK	Water	Residual Chlorine	SM4500 CI G	04/09/25 09:20		04/10/25 09:26	04/09/25
			Turbidity	SM2130 B			04/10/25 14:36	
Q1759-02	B2-W8-RM1010-SINK	Water	Residual Chlorine	SM4500 CI G	04/09/25 09:25		04/10/25 09:38	04/09/25
			Turbidity	SM2130 B			04/10/25 14:44	
Q1759-03	B2-W8-RM1011-RHSI NK	Water	Residual Chlorine	SM4500 CI G	04/09/25 09:32		04/10/25 09:41	04/09/25
			Turbidity	SM2130 B			04/10/25 14:48	
Q1759-04	B2-W8-LH-DRINKING -FOUNTAIN	Water	Residual Chlorine	SM4500 CI G	04/09/25 09:38		04/10/25 09:44	04/09/25
			Turbidity	SM2130 B			04/10/25 14:52	
Q1759-05	B2-W8-RM1019-EYEW ASH	Water	Residual Chlorine	SM4500 CI G	04/09/25 09:45		04/10/25 09:47	04/09/25

## LAB CHRONICLE

Q1759-06	B2-W8-RM1040-SINK	Water	Turbidity	SM2130 B		04/10/25 14:56	04/09/25
					04/09/25 09:53		
			Residual Chlorine	SM4500 Cl G		04/10/25 09:56	
Q1759-07	B2-W8-RM1041-SINK	Water	Turbidity	SM2130 B		04/10/25 15:00	04/09/25
					04/09/25 09:58		
			Residual Chlorine	SM4500 Cl G		04/10/25 09:59	
			Turbidity	SM2130 B		04/10/25 15:04	