

Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	04/09/25 09:58
Project:	NYSOMH Emergency Service	Date Received:	04/09/25
Client Sample ID:	B2-W8-RM1041-SINK	SDG No.:	Q1759
Lab Sample ID:	Q1759-07	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.29	H	1	0.023	0.10	mg/L		04/10/25 09:59	SM 4500-Cl G-11
Turbidity	1.82		1	0.15	1.00	NTU		04/10/25 15:04	SM 2130 B-11

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits