

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1765
Project:	Linden Generating Station - Towers	Sample ID:	Q1765-02
Client ID:	TOWERS-2DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	3400		3420		1	0.47		04/11/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q1765
Project:	Linden Generating Station - Towers	Sample ID:	Q1770-02
Client ID:	COMPDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	407		411		1	1.05		04/11/2025