

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	04/10/25 12:00
Project:	Linden Generating Station - LRSA	Date Received:	04/10/25
Client Sample ID:	DSN002	SDG No.:	Q1766
Lab Sample ID:	Q1766-01	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
BOD5	26.2		1	0.20	2.00	mg/L		04/10/25 16:20	SM 5210 B-16
COD	72.1		1	1.50	10.0	mg/L		04/16/25 14:52	SM 5220 D-11
TSS	13.9		1	1.00	4.00	mg/L		04/11/25 09:40	SM 2540 D-15

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits