

Hit Summary Sheet SW-846

SDG No.: Q1944

Order ID: Q1944

Client: METEM A GE POWER Business

Project ID: Tank Farm - Acid Analysis

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : MELTED-RUBBER-SAMPLE								
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Aluminum	2.60	J	2.05	12.2	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Chromium	8.75		0.12	1.22	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Cobalt	7.24		0.24	3.66	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Copper	2.76		0.54	2.44	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Iron	25.7		9.73	12.2	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Nickel	36.6		0.32	4.88	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Selenium	2.12	J	0.63	2.44	mg/Kg
Q1944-01	MELTED-RUBBER-SAMPLE	SOIL	Zinc	5.90		0.56	4.88	mg/Kg
Client ID : CITY-WATER								
Q1944-02	CITY-WATER	Water	Barium	24.6	J	7.28	50.0	ug/L
Q1944-02	CITY-WATER	Water	Calcium	96600		117	1000	ug/L
Q1944-02	CITY-WATER	Water	Copper	536		2.30	10.0	ug/L
Q1944-02	CITY-WATER	Water	Magnesium	33400		122	1000	ug/L
Q1944-02	CITY-WATER	Water	Nickel	1.98	J	1.53	20.0	ug/L
Q1944-02	CITY-WATER	Water	Potassium	1850		459	1000	ug/L
Q1944-02	CITY-WATER	Water	Sodium	31900		434	1000	ug/L
Q1944-02	CITY-WATER	Water	Zinc	82.9		8.33	20.0	ug/L
Client ID : CHILLER-WATER								
Q1944-03	CHILLER-WATER	Water	Antimony	238	D	16.9	125	ug/L
Q1944-03	CHILLER-WATER	Water	Arsenic	57.1	D	12.8	50.0	ug/L
Q1944-03	CHILLER-WATER	Water	Calcium	2700	JD	585	5000	ug/L
Q1944-03	CHILLER-WATER	Water	Chromium	105	D	5.30	25.0	ug/L
Q1944-03	CHILLER-WATER	Water	Copper	2190	D	11.5	50.0	ug/L
Q1944-03	CHILLER-WATER	Water	Iron	542	D	58.5	250	ug/L
Q1944-03	CHILLER-WATER	Water	Lead	42.8	D	5.75	30.0	ug/L
Q1944-03	CHILLER-WATER	Water	Potassium	4180000	D	2300	5000	ug/L
Q1944-03	CHILLER-WATER	Water	Selenium	1250	D	24.1	50.0	ug/L
Q1944-03	CHILLER-WATER	Water	Sodium	777000	D	2170	5000	ug/L
Q1944-03	CHILLER-WATER	Water	Thallium	722	D	10.9	100	ug/L
Q1944-03	CHILLER-WATER	Water	Zinc	51.3	JD	41.7	100	ug/L