

Duplicate Sample Summary

Client: CDM Smith Project: Bergen Point Fueling System Client ID: MH-PDUP	SDG No.: Q1956 Sample ID: Q1947-01 Percent Solids for Spike Sample: 79.5
--	---

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Ignitability	oC	+/-20	NO		NO		1	0		05/05/2025

Duplicate Sample Summary

Client: CDM Smith Project: Bergen Point Fueling System Client ID: COMP1DUP	SDG No.: Q1956 Sample ID: Q1956-05 Percent Solids for Spike Sample: 100
---	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Corrosivity	pH	+/-20	7.52		7.53		1	0.13		05/05/2025
Reactive Cyanide	mg/Kg	+/-20	0.011	J	0.013	J	1	17		05/07/2025
Reactive Sulfide	mg/Kg	+/-20	1.59	J	1.58	J	1	0.63		05/07/2025