

## Report of Analysis

Client:	CDM Smith	Date Collected:	
Project:	Bergen Point Fueling System	Date Received:	
Client Sample ID:	BSF0605W2	SDG No.:	Q1956
Lab Sample ID:	BSF0605W2	Matrix:	Water
Analytical Method:	8015D GRO	% Solid:	0 Decanted:
Sample Wt/Vol:	5 Units: mL	Final Vol:	5 mL
Soil Aliquot Vol:	uL	Test:	Gasoline Range Organics
Extraction Type:		Injection Volume :	
GPC Factor :	PH :		
Prep Method :			

File ID/Qc Batch:	Dilution:	Date Analyzed	Prep Batch ID
FB031692.D	1	05/06/25 18:38	FB050625

CAS Number	Parameter	Conc.	Qualifier	MDL	LOQ / CRQL	Units
<b>TARGETS</b>						
GRO	GRO	166		6.00	45.0	ug/L
<b>SURROGATES</b>						
98-08-8	Alpha,Alpha,Alpha-Trifluoroto	20.1		50 - 150	101%	SPK: 20

### Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

\* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit