

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2016
Project:	Linden Generating Station - 402	Sample ID:	LB135782BS
Client ID:	LB135782BSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TPH	mg/L	+/-18	16.9		17.0		1	0.59		05/15/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2016
Project:	Linden Generating Station - 402	Sample ID:	Q2016-01
Client ID:	402DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.58		7.58		1	0		05/12/2025