

## Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	05/13/25 10:50
Project:	Linden Generating Station - Towers	Date Received:	05/13/25
Client Sample ID:	TOWER-2	SDG No.:	Q2029
Lab Sample ID:	Q2029-02	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
TDS	5090		1	1.00	10.0	mg/L		05/14/25 12:30	SM 2540 C-15
TSS	25.5		1	1.00	4.00	mg/L		05/16/25 11:25	SM 2540 D-15

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits