

Preparation Blank Summary

Client: Parkway Generation Operating LLC

SDG No.: Q2029

Project: Linden Generating Station - Towers

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB135770BL							
TDS	mg/L	< 5.0000	5.0000	U	1.0	10	05/14/2025
Sample ID: LB135797BL							
TSS	mg/L	1	2.0000	J	1	4	05/16/2025