

284 Sheffield Street, Mountainside, New Jersey 07092, Phone : 908 789 8900, Fax : 908 789 8922

## **Report of Analysis**

Client: Kinderprep Date Collected: 05/28/25 Project: Kinderprep School Drinking Water 2025 Date Received: 05/28/25 Client Sample ID: CLASSROOM-SINK-16 SDG No.: Q2145 Lab Sample ID: Q2145-14 Matrix: Water % Solid: Level (low/med): low 0

| Cas       | Parameter | Conc. | Qua. | DF | MDL  | LOQ / CR | QL | Units | Prep Date      | Date Ana.      | Ana Met. | Prep Met. |
|-----------|-----------|-------|------|----|------|----------|----|-------|----------------|----------------|----------|-----------|
| 7440-50-8 | Copper    | 31.4  |      | 1  | 0.65 | 2.00     | ug | g/L   | 05/29/25 10:11 | 06/09/25 18:48 | 200.8    |           |
| 7439-92-1 | Lead      | 0.27  | U    | 1  | 0.27 | 1.00     | ug | g/L   | 05/29/25 10:11 | 06/09/25 18:48 | 200.8    |           |

Color Before: Colorless Clarity Before: Clear Texture:

Color After: Colorless Clarity After: Clear Artifacts:

Comments: Metals Group3

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence

of interference.

OR = Over Range

N =Spiked sample recovery not within control limits