

284 Sheffield Street, Mountainside, New Jersey 07092, Phone : 908 789 8900, Fax : 908 789 8922

## **Report of Analysis**

Client: Kinderprep Date Collected: 05/28/25 Project: Kinderprep School Drinking Water 2025 Date Received: 05/28/25 Client Sample ID: CLASSROOM-SINK-3-B SDG No.: Q2145 Lab Sample ID: Q2145-21 Matrix: Water % Solid: Level (low/med): low 0

Cas	Parameter	Conc.	Qua	. DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	116		1	0.65	2.00	ug/L	06/11/25 11:40	06/11/25 20:24	200.8	
7439-92-1	Lead	0.66	J	1	0.27	1.00	ug/L	06/11/25 11:40	06/11/25 20:24	200.8	

Color Before: Colorless Clarity Before: Clear Texture:

Color After: Colorless Clarity After: Clear Artifacts:

Comments: Metals Group3

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence

of interference.

OR = Over Range

N =Spiked sample recovery not within control limits