

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2196
Project:	Linden Generating Station - Towers	Sample ID:	Q2189-02
Client ID:	MW-8-20250602DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	562		543		1	3.44		06/04/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2196
Project:	Linden Generating Station - Towers	Sample ID:	Q2197-05
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	7.90		8.00		1	1.26		06/05/2025