

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q2197
Project: Linden Generating Station - LRSA	Sample ID: Q2197-01
Client ID: DSN002DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	36.7		34.7		1	5.6		06/09/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2197
Project:	Linden Generating Station - LRSA	Sample ID:	Q2197-01
Client ID:	DSN002MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	79.4		80.4		1	1.25		06/09/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q2197
Project: Linden Generating Station - LRSA	Sample ID: Q2197-02
Client ID: DSN002DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.22		7.21		1	0.14		06/03/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2197
Project:	Linden Generating Station - LRSA	Sample ID:	Q2197-04
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	7.15		7.14		1	0.14		06/03/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2197
Project:	Linden Generating Station - LRSA	Sample ID:	Q2197-05
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	8.84		8.64		1	2.29		06/04/2025
TSS	mg/L	+/-5	7.90		8.00		1	1.26		06/05/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2197
Project:	Linden Generating Station - LRSA	Sample ID:	Q2197-06
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.96		6.97		1	0.14		06/03/2025