

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-1ST-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.27	J	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:54	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits