

**Hit Summary Sheet**  
**SW-846**

<b>SDG No.:</b>	Q2404	<b>Order ID:</b>	Q2404
<b>Client:</b>	Total Quality Environmental Inc.	<b>Project ID:</b>	Flushing Ave

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
<b>Client ID : 1ST-FL-HALLWAY-BATH-1ST-SINK-2</b>								
Q2404-06	1ST-FL-HALLWAY-BATH-1ST	Water	Lead	1.27	J	1.21	6.00	ug/L
<b>Client ID : 1ST-FL-HALLWAY-BATH-2ND-SINK-2</b>								
Q2404-08	1ST-FL-HALLWAY-BATH-2ND	Water	Lead	1.57	J	1.21	6.00	ug/L
<b>Client ID : 1ST-FL-CHILD-CARE-SINK-1</b>								
Q2404-11	1ST-FL-CHILD-CARE-SINK-1	Water	Lead	21.7		1.21	6.00	ug/L
<b>Client ID : 1ST-FL-CHILD-CARE-SINK-2</b>								
Q2404-12	1ST-FL-CHILD-CARE-SINK-2	Water	Lead	2.58	J	1.21	6.00	ug/L



# SAMPLE DATA

A

B

C

D

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-BATH-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:32	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-BATH-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:37	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-MULTIPUPOSE-ROOM-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:41	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-MULTIPUPOSE-ROOM-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:46	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-1ST-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:50	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-1ST-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.27	J	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:54	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits



## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-2ND-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 14:59	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-2ND-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.57	J	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 15:03	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-3RD-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 15:07	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-HALLWAY-BATH-3RD-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-10	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/25/25 14:50	06/27/25 15:21	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-SINK-1	SDG No.:	Q2404
Lab Sample ID:	Q2404-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	21.7	1	1.21		6.00	ug/L	06/25/25 14:50	06/27/25 15:25	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/23/25
Project:	Flushing Ave	Date Received:	06/23/25
Client Sample ID:	1ST-FL-CHILD-CARE-SINK-2	SDG No.:	Q2404
Lab Sample ID:	Q2404-12	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.58	J	1	1.21	6.00	ug/L	06/25/25 14:50	07/03/25 16:15	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N =Spiked sample recovery not within control limits

## LAB CHRONICLE

<b>OrderID:</b>	Q2404	<b>OrderDate:</b>	6/24/2025 10:09:49 AM
<b>Client:</b>	Total Quality Environmental Inc.	<b>Project:</b>	Flushing Ave
<b>Contact:</b>	Alex Rukasov	<b>Location:</b>	A42

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
<b>Q2404-01</b>	<b>1ST-FL-CHILD-CARE-B ATH-SINK-1</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-02</b>	<b>1ST-FL-CHILD-CARE-B ATH-SINK-2</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-03</b>	<b>1ST-FL-CHILD-CARE- MULTIPUPOSE-ROOM- SINK-1</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-04</b>	<b>1ST-FL-CHILD-CARE- MULTIPUPOSE-ROOM- SINK-2</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-05</b>	<b>1ST-FL-HALLWAY-BAT H-1ST-SINK-1</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-06</b>	<b>1ST-FL-HALLWAY-BAT H-1ST-SINK-2</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-07</b>	<b>1ST-FL-HALLWAY-BAT H-2ND-SINK-1</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	
<b>Q2404-08</b>	<b>1ST-FL-HALLWAY-BAT H-2ND-SINK-2</b>	<b>Water</b>			<b>06/23/25</b>			<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25	

## LAB CHRONICLE

<b>Q2404-09</b>	<b>1ST-FL-HALLWAY-BAT H-3RD-SINK-1</b>	<b>Water</b>			<b>06/23/25</b>		<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25
<b>Q2404-10</b>	<b>1ST-FL-HALLWAY-BAT H-3RD-SINK-2</b>	<b>Water</b>			<b>06/23/25</b>		<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25
<b>Q2404-11</b>	<b>1ST-FL-CHILD-CARE-S INK-1</b>	<b>Water</b>			<b>06/23/25</b>		<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	06/27/25
<b>Q2404-12</b>	<b>1ST-FL-CHILD-CARE-S INK-2</b>	<b>Water</b>			<b>06/23/25</b>		<b>06/23/25</b>
			Metals Group4	200.7		06/25/25	07/03/25